

# Monthly Fire Extinguisher Inspection Checklist

## 1. Location & Accessibility

Ensure the extinguisher is in its designated spot and unobstructed.

## 2. Physical Condition

Check for dents, corrosion, or other damage.

## 3. Pressure Gauge

Verify the needle is in the green zone, indicating proper pressure.

## 4. Seal & Tamper Indicator

Confirm the safety seal is intact and the pin is secure.

## 5. Label & Instructions

Ensure the label is legible and instructions are clear.

## 6. Hose & Nozzle

Inspect for cracks, blockages, or damage.

## 7. Weight Check

Lift to feel if the extinguisher is full; significant weight loss may indicate leakage.

## 8. Inspection Tag

Update the inspection date and initials on the tag.